

ANNEXURE ENGINEERING COLLEGE BUILDING A WING			
Name of the Building	ENGINEERING BUILDING A WING		
	Classification of building	EDUCATIONAL	Height of Building
Main Pump	0 NOS	LPM	
Diesel Pump	0 NOS	LPM	
Jockey pump	0 NOS	LPM	
Pump Electrical Panel	1 NOS	Terrace Pump	450 LPM
Wet Riser/ Down Comer	100 MM	Fire Alarm Panel	1 NOS
Fire Service Inlet	1 NOS	Number Of Wings	1
Fire Control Room	1	Court Yard	0 NOS
Terrace Water Tank	10000	Hydrant	
		U.G. Water Tank	100000

Sr. No.	List Of Equipment	Basement	Ground Floor	1ST Floor	Total	Status
1	Floor Area	NA				
2	Hydrant Valve		3	3	6	Working
3	Hose Reel		3	3	6	Working
4	Hose Box		3	3	6	Working
5	Hose pipe		3	3	6	Working
6	Branch Pipe		3	3	6	Working
7	Fire Extinguisher - ABC		6	6	12	Working
8	Fire Extinguisher - CO2		1	1	2	Working
9	Sprinkler Head		0	0	0	
10	Manual Call Point		3	3	6	Working
11	Hooter		3	3	6	Working
12	Smoke/Heat Detector		0	0	0	
13	Fire Resistant Door		0	0	0	
14	Fire Brigade Inlet		1		1	Installed

Date :- 15-12-2025



Prashan
t
Hemant
Kanetka
r

Engineer (Fire) Prashant Kanetkar
E-mail: prashantk@akagencies.com
9822823951, 9371723951
Address: Abhyankar Nagar, Nagpur, Maharashtra
440012
Date: 15-12-2025
AKA & WAP: 1/2025

Designing & Installation of
Fire Hydrant, Sprinklers, Alarm
and Fire Fighting equipments


Principal

MKSS's Cummins College of Engineering
For Women, Nagpur.

www.akagencies.in | 215, Abhyankar Nagar, Nagpur, Maharashtra
9822823951, 9371723951 | akagencies2000@yahoo.com, prashantkanetkar@yahoo.com

ANNEXURE ENGINEERING COLLEGE BUILDING B WING				
Name of the Building	ENGINEERING BUILDING B WING			
Classification of building	EDUCATIONAL	Height of Building	8.76	MTR
Main Pump	0 NOS	LPM	0	
Diesel Pump	0 NOS	LPM		
Jockey pump	0 NOS	LPM	450	
Pump Electrical Panel	1 NOS	Terrace Pump	450 LPM	
Wet Riser/ Down Comer	100 MM	Fire Alarm Panel	1 NOS	
Fire Service Inlet	1 NOS	Number Of Wings	1	
Fire Control Room	1	Court Yard Hydran	0 NOS	
Terrace Water Tank	10000 LTRS	U.G. Water Tank	100000	LTRS

Sr. No.	List Of Equipment	Basement	Ground Floor	1ST Floor	2ND Floor	3RD Floor	Total	Status
1	Floor Area	NA						
2	Hydrant Valve		3	3			6	Working
3	Hose Reel		3	3			6	Working
4	Hose Box		3	3			6	Working
5	Hose pipe		3	3			6	Working
6	Branch Pipe		3	3			6	Working
7	Fire Extinguisher - ABC		6	6			12	Working
8	Fire Extinguisher - CO2		1	1			2	Working
9	Sprinkler Head		0	0			0	
10	Manual Call Point		3	3			6	Working
11	Hooter		3	3			6	Working
12	Smoke/Heat Detector		0	0			0	
13	Fire Resistant Door		0	0			0	
14	Fire Brigade Inlet		2				2	Working

Date :- 15-12-2025



Designing & Installation of
Fire Hydrant, Sprinklers, Alarm
and Fire Fighting equipments

**Prashan
t
Hemant
Kanetka
r**

Digitally signed by Prashant Hemant Kanetkar
DN: cn=Prashant Hemant Kanetkar, o=MKSS's Cummins College of Engineering for Women, ou=Engineering Department, email=prashantkanetkar@yahoo.com, c=IN
Date: 2025.12.15 14:27:00 +05'30'

Principal

**MKSS's Cummins College of Engineering
For Women, Nagpur.**

www.akagencies.in | 215, Abhyankar Nagar, Nagpur, Maharashtra
9822823951, 9371723951 | akagencies2000@yahoo.com, prashantkanetkar@yahoo.com

FORM - B
{(see section 3 (3) and rule 4 (2))}

Certified that I / We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely:-

MAHARSHI KARVE STREE SHIKSHAN SAMSTHA
Workshop Kh. No.170/1 169/1
Mauje Sukali gupchup Taluka Hingna, Distt- Nagpur

I further certify that these installations in the above mentioned buildings are maintained in good repair and efficient conditions during the period from

1ST JANUARY 2026 TO 30TH JUNE 2026

as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah-III of 2007). The details of the inspection of installations carried out by me / us are mentioned in the report appended herewith.

Place : NAGPUR
Date : 15/12/2025

**Prasha
nt
Hema
n
t
Kane
tk
ar**

Digitally signed by Prashant Hemant Kanetkar
DN: cn=Prashant Hemant Kanetkar
E=prashantkanetkar@yahoo.com,
OU=AK AGENCIES, O=AK AGENCIES, OU=AK AGENCIES,
CN=AK AGENCIES
4500226
Prashant Hemant Kanetkar
c/o Ak Agencies, 215, Abhyankar Nagar, Nagpur,
Maharashtra - 440012, India
Prashant Hemant Kanetkar
Prashant Hemant Kanetkar
Prashant Hemant Kanetkar
Date: 15-12-2025 14:45
PDF-A version: 1.4.20



Principal
MKSSS's Cummins College of Engineering
For Women, Nagpur.

Designing & Installation of
Fire Hydrant, Sprinklers, Alarm
and Fire Fighting equipments

ANNEXURE WORKSHOP BUILDING				
Name of the Building	WORKSHOP BUILDING			
Classification of building	EDUCATIONAL		Height of Building	3.6 MTR
Main Pump	0	NOS	LPM	
Diesel Pump	0	NOS	LPM	
Jockey pump	0	NOS	LPM	
Pump Electrical Panel	1	NOS	Terrace Pur	450 LPM
Wet Riser/ Down Comer	100	MM	Fire Alarm f	1 NOS
Fire Service Inlet	1	NOS	Number Of	1
Fire Control Room			Court Yard	0 NOS
Terrace Water Tank	10000	LTRS	U.G. Water	100000

Sr. No.	List Of Equipment	Basement	Ground Floor	Total	Status
1	Floor Area	NA			
2	Hydrant Valve		2	2	Working
3	Hose Reel		2	2	Working
4	Hose Box		2	2	Working
5	Hose pipe		2	2	Working
6	Branch Pipe		2	2	Working
7	Fire Extinguisher - ABC		6	6	Working
8	Fire Extinguisher - CO2		2	2	Working
9	Sprinkler Head		0	0	
10	Manual Call Point		1	1	Working
11	Hooter		1	1	Working
12	Smoke/Heat Detector		0	0	
13	Fire Resistant Door		0	0	
14	Fire Brigade Inlet	1		1	Working
15	Flooding System		1		Working

Date :- 15-12-2025



Prashan
t
Hemant
Kanetka
r

Digitally signed by Prashan Kanetka
DN: cn=Prashan Kanetka, o=AK AGENCIES, ou=AK AGENCIES, email=prashan.kanetka@akagencies.com, c=IN

Designing & Installation of
Fire Hydrant, Sprinklers, Alarm
and Fire Fighting equipments

www.akagencies.in | 215, Abhyankar Nagar, Nagpur, Maharashtra
9822823951, 9371723951 | akagencies2000@yahoo.com, prashantkanetkar@yahoo.com

(Signature)
Principal

MKSS's Cummins College of Engineering
For Women, Nagpur.